

DekMASTER® PVC Decking Quality Control



Project Name: _____ Sign-off Below By: _____

Area Covered by QC Sheet: _____ Date: _____

Deck Membrane Installation Item	Comply Yes/No	Sign Off (Initials)	Comment
Plywood substrate s/s screw fixed to E2/AS1 specification, no loose/drummy sheets or delamination. (Refer substrate readiness sheet)			
Concrete substrate installed to E2/AS1 specification. All soft areas in concrete removed / repaired. (Refer substrate readiness sheet)			
Substrate is clean, dry, and free from foreign matter and sharp edges and within maximum moisture limits.			
Substrate installed to specified falls to outlets.			
Substrate primed - good even coverage / penetration.			
Movement joints identified and installed to approved specification / detail. (Attach detail drawings)			
Under flashings installed to all external corners and upstands. (Pay attention to parapets, gutters, and junctions)			
Gutters correctly and neatly installed, particularly the internal corners - ensure laps above roof / gutter line.			
DrainRITE roof drains installed to specification / local body requirements and watertight.			
DrainRITE overflows installed to specification / local body requirements and watertight.			
DekMASTER® adhesive within shelf life and correctly mixed.			
DekMASTER® installed to Sealco specification, ensuring adhesive applied to substrate and membrane at correct rate.			
All joins correctly heat welded and tested with a seam probe for voids.			

Note: Where an element identified in the above is not applicable, please record N/A in the comply column

No air entrapment or foreign matter contamination in joined seam.			
Where necessary, install roof vents to specification (min. two vents / roof area, with one every 50m2).			
All penetration details completed to Sealco specification including under / over flashing.			
All non-standard details installed as per pre-approved specifications (attach approved drawings).			
Any mechanical damage to DekMASTER® repaired to Sealco specification.			
Overall installation free of wrinkles, creases and splits, with no air or foreign matter entrapped.			
Job sheets completed recording area installed, date of installation, membrane batch numbers etc.			

Note: Where an element identified in the above is not applicable, please record N/A in the comply column

Priming coverage calculation:

<input style="width: 50px; height: 20px;" type="text"/> M ² Installation Area	@	<input style="width: 50px; height: 20px;" type="text"/> ltr/M ² Coverage	=	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50px; height: 20px;"></td> <td style="padding-left: 5px;">Litres required</td> </tr> <tr> <td style="width: 50px; height: 20px;"></td> <td style="padding-left: 5px;">Pails required</td> </tr> </table>		Litres required		Pails required	<input style="width: 50px; height: 20px;" type="text"/> Pails used
	Litres required								
	Pails required								

Issues to note or raised during installation:

Remedial action required:

Note of damaged areas repaired:

Attach any photographs taken during application